

SALEM WATER DEPARTMENT
53 STANTON HILL ROAD, PoBox 214 SALEM, NY 12865
Phone and Fax 854-9712 --- Email salemvwd@verizon.net

November 8th 7pm 2017

- **There are 311 meters in service.**
- **There was 1 new water hook ups this month.**
- **We had an issue with well #2. I was able to get Mark Rogers from Cambridge to come to the water barn and be able to figure out that our issue was a fuse. The VFD runs on 480 volts and we have nothing to test it.**
- **Regular upkeep and maintenance was performed.**
- **Still working with Badger meter on our new read software. I hope it will be up and running soon so we can then start working on replacing meter heads to get a better read percent.**
- **We did our fall fire hydrant flush - It went good. We do have some minor issues that we will be fixing.**
- **Eye wash and Fire Extinguishers checks have been done. All fire extinguishers for the water office passed there yearly inspection.**
- **We did our monthly water sample required by the D.O.H. MET the bacteriological requirements for a public water supply as set forth in subpart 5-1.5 of the State Sanitary Code under Public Heath Law 225.**
- **We have been getting the Fire Hydrants all ready for winter. We cleaned the caps - put a food grade lube on them and also pump the water out so they will not freeze.**

Thank You,
Eric Rogers
Class C Water Plant Operator

I would like to ask the Fire Department to notify Eric or Travis if a hydrant is used so we can make sure it gets re-winterized.